

April 16, 2026

306-741-5421

Via Email: cao@gravelbourg.ca; eng@gravelbourg.ca

Town of Gravelbourg  
Box 359  
GRAVELBOURG SK S0H 1X0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Town of Gravelbourg: 2ND, 3RD AND 4TH Block of Main Street* - Rescinded


The Water Security Agency, in consultation with Saskatchewan Health Authority is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the *Town of Gravelbourg*’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of two (4 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-741-5421 or Andrew.Hickey@wsask.ca.

Sincerely,



Andrew Hickey  
Environment Officer  
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Moose Jaw Office